

E. Runyon T/A Aquatic Services

464 Preventorium Rd.
Howell, NJ 07731
aquatic464@verizon.net
732-938-6366

NJ Certified Laboratory #
13052

Date	Invoice #
5/6/2021	17624

Bill To
CPC Behavioral Healthcare Facilities Director, Rick Gonzalez 10 Industrial Way East Eatontown, NJ 07724-3317

Purchase Order #:

Quantity	Description	Rate	Amount
11	Lead water analysis performed as required: Sample Date: 4/17/21	41.00	451.00
	Sales Tax	6.625%	0.00
Due net within 30 days. 1 1/2% Service Charge Per Month On All Past Due Accounts.		Total	\$451.00

E. Runyon T/A Aquatic Services
 464 Preventorium Rd.
 Howell, NJ 07731
 732-938-6366

Chain of Custody

New Jersey Certified Lab. ID # 13052

Location/Description	Sample ID	Date	Time	Sampler Pres.	Analysis Date/Time	Tech.	Analysis
<p>Lead and Copper Rule</p> <p>Please collect samples after water has remained motionless in the pipes for 6 hrs or more from separate spigots. Cold water.</p> <p>Do not allow any water to run down the drain. Fill each bottle to top.</p> <p>Record locations, date and time of each sample collected.</p> <p>Call us once sample have been collected to schedule a pick up.</p> <p>No refrigeration is necessary. Samples have a long holding time.</p>							
CPC Mental Health Services							
record locations:							
NURSES OFFICE 1 ST FLOOR	CPC1	4/17/21	9:45				Lead
ROOM 103 1 ST FLOOR	CPC2	4/17/21	9:49				Lead
ROOM 121 1 ST FLOOR	CPC3	4/17/21	9:49				Lead
ROOM 105 STAFF LOUNGE (SL)	CPC4	4/17/21	9:50				Lead
ROOM 232 STAFF LOUNGE(SL)	CPC5	4/17/21	9:52				Lead
ROOM 248 USE SEVERAL (LS)	CPC6	4/17/21	9:53				Lead
HP DISH SINK BLDG. #3	CPC7	4/17/21	10:00				Lead
HP TRIPLE SINK BLDG. #3	CPC8	4/17/21	10:00				Lead
STAFF KITCHEN BLDG. #3	CPC9	4/17/21	10:02				Lead
STAFF KITCHEN BLDG. #4 (ANUS)	CPC10	4/17/21	10:10				Lead
KITCHEN SINK BLDG. #2	CPC11	4/17/21	10:13				Lead
	CPC12	4/17/21					Lead

Relinquished by: _____

Date/Time: _____

Received by: *Randy P. ...*

NOTE: * indicates preservative used was 10% sodium thiosulfate.

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

CPC Mental Health Services

SAMPLE #	PBCU #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME/CODE	ANALYTICAL METHOD	MRL	RESULTS MGL	ANALYSIS DATE/TIME
CPC1	N/A	Nurses Office – 1 st Floor	4-17-21	09:45	LEAD/1030	200.9	0.002	<0.002	4-22-21/12:56
CPC2	N/A	Room 103 – 1 st Floor	4-17-21	09:49	LEAD/1030	200.9	0.002	<0.002	4-22-21/13:02
CPC3	N/A	Room 121 – 1 st Floor	4-17-21	09:49	LEAD/1030	200.9	0.002	<0.002	4-22-21/13:09
CPC4	N/A	Room 105 – Staff Lounge	4-17-21	09:50	LEAD/1030	200.9	0.002	<0.002	4-22-21/13:16
CPC5	N/A	Room 232 – Staff Lounge	4-17-21	09:52	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:02
CPC6	N/A	Room 248 – Life Skills	4-17-21	09:53	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:09
CPC7	N/A	HP Dish Sink – Bldg. #3	4-17-21	10:00	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:15
CPC8	N/A	HP Triple Sink – Bldg. #3	4-17-21	10:00	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:22
CPC9	N/A	Staff Kitchen – Bldg. #3	4-17-21	10:02	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:29
CPC10	N/A	Staff Kitchen – Bldg. #4 Annex	4-17-21	10:10	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:35
CPC11	N/A	Kitchen Sink – Bldg. #2	4-17-21	10:13	LEAD/1030	200.9	0.002	<0.002	4-22-21/14:42

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).
pH expressed in units
< = Less Than
MRL = Minimum Reporting Limit

Examined By: *Margaret Ellis*
Lab Manager

Date: 4-29-21